

Mystique 5-Wire Wiring Diagram for Digital Systems

Use the following to wire a Mystique Smart Station. Digital systems are Touchplate systems. Each system will have different components and this document does not show all possible connections.

Button Layout



Wiring Information

- Can be home runned, daisy chained, or a combination of both
- Touchplate recommends the use of 22/01PSH+ 18/2C or equivalent wire
- **Shield or Ground must be isolated from the ground on the power supply. Using the same ground will create a direct short and damage the unit.**

Communicating to and Powering the Station

- Power will typically come from a Smart Control Gateway, Smart Control Link, or Time-Keeper® Max
- Communication and data terminals are typically labeled as GND, -, and +.



